



Model Number	Nominal Size (Inches) W x H x D	Actual Size (Inches) W x H x D	Rated Air Flow (CFM)	Initial Resistance (In. W.G.)	Media Area (Square Feet)
MX40-STD2-217	10 X 20 X 2	9-1/2 X 19-1/2 X 1-3/4	700	0.21	4.1
MX40-STD2-222	12 X 12 X 2	11-3/4 X 11-3/4 X 1-3/4	500	0.21	3.1
MX40-STD2-220	12 X 20 X 2	11-1/2 X 19-1/2 X 1-3/4	840	0.21	5.2
MX40-STD2-210	12 X 24 X 2	11-3/8 X 23-3/8 X 1-3/4	1000	0.21	6.2
MX40-STD2-239	14 X 20 X 2	13-1/2 X 19-1/2 X 1-3/4	980	0.21	5.7
MX40-STD2-241	14 X 25 X 2	13-1/2 X 24-1/2 X 1-3/4	1220	0.21	7.1
MX40-STD2-245	15 X 20 X 2	14-1/2 X 19-1/2 X 1-3/4	1050	0.21	6.2
MX40-STD2-243	16 X 16 X 2	15-3/4 X 15-3/4 X 1-3/4	890	0.21	6.7
MX40-STD2-201	16 X 20 X 2	15-1/2 X 19-1/2 X 1-3/4	1120	0.21	6.7
MX40-STD2-216	16 X 24 X 2	15-3/8 X 23-3/8 X 1-3/4	1340	0.21	8.0
MX40-STD2-202	16 X 25 X 2	15-1/2 X 24-1/2 X 1-3/4	1400	0.21	8.0
MX40-STD2-263	18 X 18 X 2	17-3/4 X 17-3/4 X 1-3/4	1125	0.21	7.0
MX40-STD2-280	18 X 20 X 2	17-1/2 X 19-1/2 X 1-3/4	1250	0.21	7.7
MX40-STD2-282	18 X 22 X 2	17-1/2 X 21-1/2 X 1-3/4	1375	0.21	9.3
MX40-STD2-212	18 X 24 X 2	17-3/8 X 23-3/8 X 1-3/4	1500	0.21	9.3
MX40-STD2-285	18 X 25 X 2	17-1/2 X 24-1/2 X 1-3/4	1570	0.21	9.7
MX40-STD2-203	20 X 20 X 2	19-1/2 X 19-1/2 X 1-3/4	1400	0.21	8.3
MX40-STD2-211	20 X 24 X 2	19-3/8 X 23-3/8 X 1-3/4	1670	0.21	9.9
MX40-STD2-204	20 X 25 X 2	19-1/2 X 24-1/2 X 1-3/4	1750	0.21	10.3
MX40-STD2-232	20 X 30 X 2*	19-1/2 X 29-1/2 X 1-3/4	2085	0.21	12.9
MX40-STD2-205	24 X 24 X 2	23-3/8 X 23-3/8 X 1-3/4	2000	0.21	11.7
MX40-STD2-225	25 X 25 X 2	24-1/2 X 24-1/2 X 1-3/4	2170	0.21	12.9

\* Reverse Pleat Direction

**STANDARD CONSTRUCTION**

1. 100% Synthetic Thermally Bonded White Media
2. 10.0 Pleats Per Foot
3. Expanded Metal Pleat Supports
4. Moisture Resistant Beverage Board Frame
5. Double Wall Frame

**NOTES**

1. MERV 8 per ASHRAE 52.2-2012  
MERV 8-A Per ASHRAE 52.2-2012 Appendix J.  
Performance Data at 492 FPM on 24x24x2 Face Size
2. Final Resistance: 1.0" W.G.
3. Rated Velocity: 500 FPM
4. Classified Per UL Standard 900 for Flammability
5. Maximum Operating Temperature: 225 DEG. F



100 River Ridge Circle  
Jeffersonville, IN 47130  
P: 866-247-4827  
F: 866-801-1809  
www.dlcair.com/airguard

**CONTACT FACTORY TO  
VERIFY REVISION LEVEL**

TOLERANCES UNLESS OTHERWISE SPECIFIED	
FRACTIONAL	-
DECIMAL	-
ANGLES	-
ALL DIMENSIONS IN INCHES	

DRAWING NAME <b>DP MAX PLEAT (2" DEPTH)</b>			
APPROVED BY <i>K. Quinn</i>	SPECIFICATION NO. <b>MKT-B-00549</b>	PAGE <b>1 OF 1</b>	
SCALE <b>NONE</b>	DWG. SIZE <b>A</b>	REVISION <b>E</b>	REVISION DATE <b>03-23-16</b>
CONFIDENTIAL - DO NOT COPY. THIS MATERIAL IS TRADE SECRET AND PROPRIETARY BEING EXCLUSIVELY OWNED BY CLC AIR. THE EXPRESSION OF THE INFORMATION CONTAINED HEREIN IS PROTECTED UNDER FEDERAL COPYRIGHT LAWS AND ALL COPYING IS PROHIBITED AND MAY BE SUBJECT TO CRIMINAL PENALTIES.			